



INDICATIVE PROPOSED NEWBRIDGE TRANSPORT PLAN NEARSIDE JUNCTION LAYOUT.


PROPOSED ON-LINE HYDRANT AS PER IRISH WATER STANDARD DETAIL REF. STD-W-18.

PROPOSED BULK WATER METER AS PER IRISH WATER STANDARD DETAIL REF. STD-W-26 COMPLETE WITH WASHOUT HYDRANT.

PROPOSED CONNECTION TO BE MADE TO EXISTING 300MM DIAMETER IRISH WATER WATERMAIN IN ATHGARVAN ROAD. DETAILS TO BE AGREED WITH IRISH WATER.

PROPOSED SERVICE CONNECTION TO PLANT ROOM. SIZE TO BE CONFIRMED BY M+E ENGINEER.

LEGEND:	
EXISTING WATERMAIN SIZE AS SHOWN.....	— EXST_WM —
EXISTING SLUICE VALVE	SV
EXISTING WATER METER	(M)
PROPOSED 150mm WATERMAIN.....	— 150 WM —
PROPOSED SLUICE VALVE.....	SV
PROPOSED AIR VALVE.....	AV
PROPOSED FIRE HYDRANT.....	(H)
PROPOSED BULK METER.....	(M)



- NOTES**
- ALL DIMENSIONS ARE IN METRES UNLESS OTHERWISE STATED.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS. ANY DISCREPANCIES, ERRORS OR OMISSIONS TO BE BROUGHT TO THE ATTENTION OF THE DESIGNER.
 - ALL DIMENSIONS TO BE CHECKED BY THE CONTRACTOR ON SITE PRIOR TO COMMENCEMENT OF WORKS.
 - AECOM LIMITED TO BE INFORMED BY THE CONTRACTOR OF ANY DISCREPANCIES PRIOR TO THE COMMENCEMENT OF WORKS ON SITE.
 - DIMENSIONS OF ALL BOUNDARIES AND ADJOINING ROADS TO BE CHECKED ON SITE PRIOR TO COMMENCEMENT OF WORKS.
 - DO NOT SCALE. ALL MEASUREMENTS AND COORDINATES TO BE CHECKED ON SITE.

ISSUE/REVISION	
2	10.03.2023 UPDATED PART 8 ISSUE
1	07.10.2022 PART 8 ISSUE
0	14.03.2022 DRAFT STAGE 2 ISSUE
I/R	DATE DESCRIPTION

This drawing has been prepared for the use of AECOM's client. It may not be used, modified, reproduced or relied upon by third parties, except as required by law. AECOM accepts no responsibility, and denies any liability, whatsoever, to any party that uses or relies on this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from the stated dimensions.